

**Bus Garage**

PRIORITY	WEIGHTED PRIORITY	CODE #	CONST YR	WORK ITEM - DESCRIPTION
2		1	2010	Interior Electrical Distribution (5 Years Remaining) Replace MDP & BC Panels
1		4	2010	Hot Water Heaters (5 Years Remaining)
1		1	2010	Emergency Exit Lighting System (5 Years Remaining)
2		1	2010	Bus Lift. Both lifts are original and (1) is non-operational.
1		4	2015	Pavement (Roads and Parking Areas (10 Years Remaining))
1		4	2015	Sidewalks (10 Years Remaining)
		1	2015	<del>Communication Systems (10 Years Remaining) Fed from High School, phones only. Complete EXCEL Project.</del>
1		1	2020	Water Service (15 Years Remaining)
1		1	2020	Roof & Skylights (15 Years Remaining) Roof Replacement Needed
1		4	2020	Floor Finishes (15 Years Remaining) Some VAT Tiles are existing
1		1	2020	Ceilings (15 Years Remaining)
1		4	2020	Lighting Fixtures (15 Years Remaining)

Code

1=Health/Safety

2=SED MPS/Bldg Code

3=ADA

4=Infrastr/Reconst

5=Prog Needs

6=Prog Requests

Priority

1=Major Capital Project (3-5 years)

2=Minor Capital Project (1-2 years)

PRIORITY	WEIGHTED PRIORITY	CODE #	CONST YR	WORK ITEM - DESCRIPTION
1		1	2025	Site Sanitary (20 Years Remaining)
1		1	2025	Site Fuel Oil (20 Years Remaining)
1		4	2025	Site Storm Drainage (20 Years Remaining)
1		1	2025	Site Electric (20 Years Remaining)
1		1	2025	Chimneys (20 Years Remaining)
1/2		4	2025	Exterior Doors ( 20 Years Remaining). <i>Per Owner, 2 overhead doors are 2-3 years old - good condition but 2 man doors at the back need to be replaced.</i>
1		4	2025	Windows (20 Years Remaining)
1		1	2025	Interior Bearing Walls and Fire Walls (20 Years Remaining)
-		1	2025	Other Interior Walls (20 Years Remaining)
1		4	2025	Interior Doors (20 Years Remaining)
-		1	2025	Plumbing Drainage System (20 Years Remaining)
-		4	2025	Plumbing Fixtures (20 Years Remaining)

Code

1=Health/Safety

2=SED MPS/Bldg Code

3=ADA

4=Infrastr/Reconst

5=Prog Needs

6=Prog Requests

Priority

1=Major Capital Project (3-5 years)

2=Minor Capital Project (1-2 years)

PRIORITY	WEIGHTED PRIORITY	CODE #	CONST YR	WORK ITEM - DESCRIPTION
-		1	2025	Hot Water Boiler (20 Years Remaining)
-		1	2025	Heating Fuel/Energy System (20 Years Remaining)
-		1	2025	Air Handling Units (20 Years Remaining)
-		1	2025	Piped Heating and Cooling System (20 Years Remaining)
-		1	2025	Ducted Heating and Cooling System (20 Years Remaining)
1		1	2025	HVAC Control System (20 Years Remaining). <i>Per Owner, there is a fan that runs continually needs to be investigated.</i>
-		1	2030	Foundations (25 Years Remaining)
-		1	2030	Structural Floors (25 Years Remaining)
-		1	2030	Exterior Walls/Columns (25 Years Remaining)
-		1	2030	Water Distribution System (25Years Remaining)

Code

1=Health/Safety

2=SED MPS/Bldg Code

3=ADA

4=Infrastr/Reconst

5=Prog Needs

6=Prog Requests

Priority

1=Major Capital Project (3-5 years)

2=Minor Capital Project (1-2 years)